

State & Federal PFAS Drinking Water Standards

Compound	Federal Standard		Alaska Standard	California Standard	
	Drinking Water Health Advisory	ATSDR Draft Minimum Risk Levels	Drinking Water Action Level (Individually or Combined)	Drinking Water Notification Levels	Drinking Water Response Levels
PFOS	70 ppt	52 ppt (adult) 14 ppt (child)	70 ppt	6.5 ppt	40 ppt
PFOA	70 ppt	78 ppt (Adult) 21 ppt (child)	70 ppt	5.1 ppt	10 ppt
PFNA		78 ppt (adult) and 21 ppt (child)			
PFHxS		517 ppt (adult) and 140 ppt (child)			
PFHpA					
PFBS					
PFHxA					
PFBA					
PFUnDA					
PFTrDA					
PFTeDA					
PFPeA					
PFHpS					
PFDS					
PFDoDA					
PFDA					
MeFOSE					
MeFOSA					
FOSA					
EtFOSE					
EtFOSA					
8:2 FTSA					
6:2 FTSA					
HFPO-DA					

Compound	Connecticut Standard	Maine Standard	Massachusetts Standard	Michigan Standard	Minnesota Standard
	Drinking Water Action Level (Individually or Combined)	Drinking Water Program Guidance (Individually or Combined)	Drinking Water MCLs (Individually or Combined)	Adopted MCLs	Health Based Drinking Water Standards
PFOS	70 ppt	70 ppt	20 ppt	16 ppt	15 ppt
PFOA	70 ppt	70 ppt	20 ppt	8 ppt	35 ppt
PFNA	70 ppt		20 ppt	6 ppt	
PFHxS	70 ppt		20 ppt	51 ppt	47 ppt
PFHpA	70 ppt		20 ppt		
PFBS				420 ppt	2,000 ppt
PFHxA				400,000 ppt	
PFBA					7,000 ppt
PFUnDA					
PFTTrDA					
PFTeDA					
PFPeA					
PFHpS					
PFDS					
PFDoDA					
PFDA			20 ppt		
MeFOSE					
MeFOSA					
FOSA					
EtFOSE					
EtFOSA					
8:2 FTSA					
6:2 FTSA					
HFPO-DA				370 ppt	

Compound	New Hampshire Standard	New Jersey Standard	New York Standard	Ohio Standard	Rhode Island Standard
	Drinking Water MCLs (Injunction Issued Barring Enforcement)* * The former AGQS rule of 70 ppt for PFOA, PFOS, or combined concentrations of the two chemicals, as adopted by NHDES in 2016, remains in effect, while the 2019 rules are under an injunction.	Adopted Drinking Water MCLs	Adopted MCLs	Drinking Water Action Levels * Individually or combined with PFOS or PFOA	Proposed Drinking Water Standards
PFOS	15 ppt	13 ppt	10 ppt	70 ppt*	20 ppt
PFOA	12 ppt	14 ppt	10 ppt	70 ppt*	20 ppt
PFNA	13 ppt			20 ppt	20 ppt
PFHxS	18 ppt			140 ppt	20 ppt
PFHpA					20 ppt
PFBS				140,000 ppt	
PFHxA					
PFBA					
PFUnDA					
PFTTrDA					
PFTeDA					
PFPeA					
PFHpS					
PFDS					
PFDoDA					
PFDA					
MeFOSE					
MeFOSA					
FOSA					
EtFOSE					
EtFOSA					
8:2 FTSA					
6:2 FTSA					
HFPO-DA					

Compound	Vermont Standard	Washington Standard
	Adopted MCLs (The sum of these five PFAS cannot exceed 20 ppt)	Proposed Drinking Water Action Levels
PFOS	20 ppt	15 ppt
PFOA	20 ppt	10 ppt
PFNA	20 ppt	
PFHxS	20 ppt	70 ppt
PFHpA	20 ppt	
PFBS		1,300 ppt
PFHxA		
PFBA		
PFUnDA		
PFTTrDA		
PFTeDA		
PFPeA		
PFHpS		
PFDS		
PFDoDA		
PFDA		
MeFOSE		
MeFOSA		
FOSA		
EtFOSE		
EtFOSA		
8:2 FTSA		
6:2 FTSA		
HFPO-DA		